

FIRE SAFETY

INTRODUCTION

Fire safety is the set of practices intended to reduce the destruction caused by fire. Fire safety measures include those that are intended to prevent ignition of an uncontrolled fire, and those that are used to limit the development and effects of a fire after it starts. Fire safety measures include those that are planned during the construction of a building or implemented in structures that are already standing, and those that are taught to occupants of the building. Threats to fire safety are commonly referred to as fire hazards. A fire hazard may include a situation that increases the likelihood of a fire or may impede escape in the event a fire occurs. Fire safety is often a component of building safety.

The staff/employees should have a working knowledge of basic fire science and chemistry. A fire, or combustion, is a chemical reaction. An understanding of the chemical reaction is the basis for preventing fires, as well as extinguishing fires once they initiate. A working knowledge of basic fire science and chemistry is essential for developing and implementing a successful fire safety program.

DEFINITION OF FIRE

A fire is a chemical reaction. There are many variables that can affect a fire. Effective fire safety management programs control the variables that can affect a fire. Therefore, it is imperative to understand the variables. A fire is self-sustained oxidation of a fuel that emits heat and light. A fire requires three variables to initiate: a fuel, oxygen, and heat.

The fire triangle is a well-known representation of the three variables needed to initiate a fire. In order to initiate a fire, fuel, oxygen, and heat are required.


FIRE TETRAHEDRON

Fire prevention is the concept of preventing the variables of the fire triangle from coming into contact with each other to initiate a fire. Once a fire begins, it requires four variables to sustain the combustion reaction. The four variables required to sustain a fire are fuel, oxygen, heat, and chemical chain reactions. These four variables represent the fire tetrahedron.

Chemical chain reactions are a product of the combustion process. The chemical reactions ultimately produce combustion byproducts such as carbon monoxide, carbon dioxide, carbon, and other molecules, depending on the specific fuel. It is these byproducts of combustion found in the smoke that usually affect the safety and health of occupants and fire fighters.

Once a fire begins and is self-sustaining, the goal is to control and extinguish the fire. Fire extinguishment is done by eliminating one of the variables of the fire tetrahedron. By removing the fuel, oxygen, or heat, or inhibiting the chemical chain reactions, a fire can be extinguished. The concept of fire protection assumes fires will occur, and focuses on controlling fires by eliminating or otherwise controlling the variables of the fire tetrahedron. The concept of fire prevention differs from fire protection because fire prevention attempts to control the variables of the fire triangle before a fire occurs.

THE FIRE TETRAHEDRON



To further understand the fire triangle, it is necessary to analyze what influence each side of the fire triangle has in the combustion process. For the safety manager, this analysis is the key for understanding the concept of fire prevention. Fire prevention attempts to prevent fuels, oxygen, and heat from combining to start a fire. Fire prevention strategies include controlling fuels, controlling oxygen sources, and controlling heat sources. A discussion of fuels, oxygen, and heat sources follows.

FUEL:

A fuel is a combustible solid, liquid, or gas. Like in any chemical reaction, a source of energy is needed to sustain the heat required. The most common solid fuels are wood, paper, cloth, coal, and so forth. Flammable and combustible liquids include gasoline, fuel oil, paint, kerosene, and other similar materials. Propane, acetylene, and natural gas are some examples of gases that are flammable. Solid and liquid fuels share a common characteristic; they must be converted into a gas in order to support combustion. Gaseous fuels can undergo direct oxidation because the molecules are already in the gas state. Some liquid fuels can undergo direct oxidation because they produce vapors at ambient temperatures and pressures. Other liquid fuels and solid fuels, however, undergo sequential oxidation. This means that a fuel must be heated first to produce sufficient concentrations of gas to support combustion. From a fire safety standpoint, the safety manager should be aware of the different types of fuels located in the workplace.

The ease of ignition of a solid fuel is dependent on several factors. The most important factor is the surface to mass ratio of the fuel. The surface to mass ratio refers to how much of a fuel's surface area is exposed to the environment in relation to its overall mass. The safety manager should be concerned with two things regarding the surface to mass ratio of a fuel. First, the more surface area that is exposed, the easier it is for a fire to initiate and the more rapidly it can burn. Second, the more mass that a solid fuel has, the more difficult it will be to initiate and sustain combustion. Consider cotton as a fuel in a textile mill. Cotton dusts and lint will burn easier and faster than a tightly bound bale of cotton. Liquid fuels are affected by several factors. The safety manager should be familiar with the terms flash point, fire point, boiling point, and specific gravity. Chapter 4 explores these factors in detail. However, one

of the most critical indicators of a liquid's flammability should be mentioned—flash point. The flash point refers to the temperature at which adequate vapors are produced to form an ignitable mixture in air. Therefore, a liquid heated to a temperature at or above its flash point will ignite in the presence of an ignition source such as a spark, cigarette, hot surface, or open flame.

OXYGEN:

The atmosphere contains approximately 21% oxygen by volume. During combustion, the oxygen necessary for oxidation is sufficiently provided from the surrounding air. When the oxygen content of the atmosphere falls below 15%, a free-burning fire will begin to smolder. When the oxygen content of the atmosphere falls below 8%, a smoldering fire will stop burning (Bryan, 1982). Oxygen can also be provided by other sources that release oxygen molecules during a chemical reaction. The safety manager should be aware of these oxidizers in the workplace and segregate them from any fuels.

HEAT:

The safety manager should be concerned with sources of heat commonly found in the workplace. This is a concern because sources of heat provide the energy necessary to initiate combustion. By preventing heat sources from contacting the ignitable fuel-air mixtures, fires can be effectively prevented from occurring. Some common sources of heat for ignition in the workplace are:

- Open flames such as from cutting and welding torches
- Cigarettes
- Sparks such as from electrical equipment, brazing, or grinding
- Hot surfaces such as electrical motors, wires, and process pipes
- Radiated heat from boilers or portable heaters
- Lightning
- Static discharges such as during the transfer of flammable liquids
- Arcing from wires and electrical equipment
- Compression such as hydraulic oil under pressure on a machine
- Exothermic chemical reactions
- Spontaneous ignition from slow oxidation or fermentation combined with proper insulation of a fuel

Heat is transferred by three methods: conduction, convection, or radiation. Conduction occurs when two bodies are touching one another and heat is transferred from molecule to molecule. Convection is the transfer of heat through a circulating medium rather than by direct contact. The medium can be either a gas or a liquid. Radiation is the transfer of electromagnetic waves through any medium. For the safety manager, recognizing how heat can be transferred in the workplace is helpful for preventing fires.

As mentioned, four fire extinguishing principles exist. They are highlighted below:

1. Control the fuel— Controlling the fuel is accomplished by two methods. First, the fuel can be physically removed or separated from the fire. For instance, a fire involving stacks of wood pallets could be controlled by removing any exposed stacks of pallets to a safe location. Another example is closing a valve feeding a gas or flammable liquid fire. Second, the fuel can be chemically affected by diluting the fuel.

2. Control the oxygen— Controlling the oxygen requires that the oxygen be inhibited, displaced, or the concentration of oxygen be reduced below 15% by volume. Smoldering fires should be diluted to an oxygen concentration below 8% by volume. The oxygen supply to a fire can be inhibited by smothering the fire. Smothering a fire places a barrier between the flame and the atmosphere. This can be accomplished with a blanket or applying a layer of foam to form a vapor barrier. Displacing and reducing the oxygen concentration involves applying an inert gas to the fire, such as carbon dioxide. The carbon dioxide displaces the oxygen thus lowering the concentration to a level that cannot sustain the fire. Applying an inert gas to a fire requires that the fire be located in a confined space. Personnel must be aware

that displacing the oxygen or diluting the oxygen concentration affects their ability to breathe. Fire extinguishment using this method requires that personnel be absent from the confined area or protected by self-contained breathing apparatus.

3. Control the heat— Controlling the heat requires that the heat be absorbed. Combustion is an exothermic chemical reaction. If the heat emitted by the reaction can be absorbed faster than the reaction can produce the heat, then the reaction cannot be sustained. Water is the most common extinguishing agent. Water is also the most efficient extinguishing agent because it has the capability to absorb immense amounts of heat.

4. Inhibit the chemical chain reactions— Inhibiting the chemical chain reactions requires that a chemical agent be introduced into the fire. Certain chemical agents can interfere with the sequence of reactions by absorbing free radicals from one sequence that are needed to complete the next sequence. Dry chemical extinguishing agents commonly used in portable fire extinguishers have this ability.

CLASSES OF FIRE

Fires are classified based upon the type of fuel that is consumed. Fires are classified into categories so personnel can quickly choose appropriate extinguishing agents for the expected fire and associated hazards. Fires are classified into five general classes. Each class is based on the type of fuel and the agents used in extinguishment. The five classes of fire are described next:

- **Class A—** Class A fires involve ordinary combustibles such as wood, paper, cloth, rubber, and some plastics. Water is usually the best extinguishing agent because it can penetrate fuels and absorb heat. Dry chemicals used to interrupt the chemical chain reactions are also effective on Class A fires.
- **Class B—** Class B fires involve flammable and combustible liquids and gases such as gasoline, alcohols, and propane. Extinguishing agents that smother the fire or reduce the oxygen concentration available to the burning zone are most effective. Common extinguishing agents include foam, carbon dioxide, and dry chemicals.
- **Class C—** Class C fires involve energized electrical equipment. Non-conductive extinguishing agents are necessary to extinguish Class C fires. Dry chemicals and inert gases are the most effective agents. If it can be done safely, personnel should isolate the power to electrical equipment before attempting to extinguish a fire. Once electrical equipment is de-energized, it is considered a Class A fire.
- **Class D—** Class D fires involve combustible metals such as magnesium, sodium, titanium, powdered aluminum, potassium, and zirconium. Class D fires require special extinguishing agents that are usually produced for the specific metal.
- **Class K—** Class K fires most often occur where cooking media (fats, oils, and greases) are used, and most of the time are found in commercial cooking operations. Class K fire extinguishers are required in any location that cooks oils, grease, or animal fat. Any location that fries must have a Class K fire extinguisher. Every commercial kitchen should have a Class K extinguisher located in it to supplement the suppression system.

THREE STAGES OF FIRE

Fires evolve through several stages as the fuel and oxygen available are consumed. Each stage has its own characteristics and hazards that should be understood by safety managers and fire-fighting personnel.

INCIPIENT STAGE:

The incipient stage is the first or beginning stage of a fire. In this stage, combustion has begun. This stage is identified by an ample supply of fuel and oxygen. The products of combustion that are released during this stage normally include water vapor, carbon dioxide, and carbon monoxide. Temperatures at the seat of the fire may have reached 1000°F, but room temperatures are still close to normal.

FREE-BURNING STAGE:

The free-burning stage follows the incipient stage. At this point, the self-sustained chemical reaction is intensifying. Greater amounts of heat are emitted and the fuel and oxygen supply is rapidly consumed. Room temperatures can rise to over 1300°F. In an enclosed compartment, the free-burning stage can become dangerous. Because of the heat intensity, the contents within a compartment are heated. At some point, if the compartment is not well ventilated, compartment contents will reach their ignition temperature. A flashover occurs when the contents within a compartment simultaneously reach their ignition temperature and become involved in flames. It is not uncommon for room temperatures to exceed 2000°F following a flashover. Human survival, even for properly protected fire fighters, is difficult if not impossible for a few seconds within a compartment following a flashover.

SMOLDERING STAGE:

The smoldering stage follows the free-burning stage. As a free-burning fire continues to burn, the chemical reaction will eventually consume the available oxygen within the compartment and ultimately convert it into carbon monoxide and carbon dioxide. This causes the oxygen concentration within the compartment to decrease. When the oxygen concentration decreases to 15% by volume, the chemical reaction will not have sufficient oxygen to support free-burning combustion. Visibly, the flames subside and the fuel begins to glow. A smoldering fire is identified by a sufficient amount of fuels and lower oxygen concentrations. Smoldering fires, especially when insulated within a compartment, can continue the combustion process for hours. Room temperatures can range from 1000–1500°F. The byproducts of combustion also fill the compartment and human survival is impossible. During the smoldering stage, an extreme hazard, called a backdraft, can develop. A backdraft occurs when oxygen is introduced into a smoldering compartment fire. The immediate availability of sufficient oxygen in the presence of sufficient fuel, heat, and chemical chain reactions causes flaming combustion again. In some cases, the backdraft is so violent that an explosion will occur. Human survival, even of properly protected fire fighters, is usually not possible.

IDENTIFICATION OF HAZARDOUS MATERIALS

In the past, chemical manufacturers labeled their products with the warnings “Caution,” “Danger,” and “Handle with Care.” The terms were vague and did not indicate specific hazards associated with particular chemicals. The U.S. Department of Transportation labeling system contains requirements for the shipping, marking, labeling, and placarding of 1400 hazardous materials.

The objectives of this standard are to

- (1) Provide an immediate warning of potential danger;
- (2) Inform emergency responders of the nature of the hazard;
- (3) State emergency spill or release control procedures; and
- (4) Minimize potential injuries from chemical exposure.

The standard contains a hazardous materials table listing substances by name, prescribing requirements for shipping papers, package marking, labeling, and transport vehicle placarding. Table shows a comparison listing of

United Nations and DOT classifications for hazardous materials. The classes of hazardous materials that must be labeled and placarded are as follows: explosives, flammable and combustible materials, oxidizers, corrosives, poisons, compressed gases, etiologies, and radioactive materials.

TABLE 1
United Nations and Department of Transportation Classification of Hazardous Materials

United Nations Class	DOT Classification
1	Explosives: Class A, B, and C
2	Nonflammable and flammable gases
3	Flammable liquids
4	Flammable solids, spontaneously combustible substances, and water reactive substances
5	Oxidizing materials and organic peroxides
6	Poisons: Class A, B, and C
7	Radioactive I, II, and III
8	Corrosives
9	Miscellaneous materials which can present a hazard during transport, but are not covered by other classes

TABLE 2
Table of Evacuation (Isolation) Distances

1. Determine if the accident involves a *small* or *large* spill and if *day* or *night*. Generally, a *small spill* is one which involves a single, small package (i.e., up to a 208 liter [55 U.S. gallon] drum), a small cylinder, or a small leak from a large package. A *large spill* is one which involves a spill from a large package, or multiple spills from many small packages.
2. Determine the initial *isolation* distance. Direct all persons to move, in a crosswind direction, away from the spill to the distance specified in meters and feet.
3. Next, determine the initial *protective action distance*. For a given dangerous goods, spill size, and whether day or night, try to determine the downwind distance—in kilometers and miles—for which protective actions should be considered. For practical purposes, the Protective Action Zone (i.e., the area in which people are at risk of harmful exposure) is a square, whose length and width are the same as the downwind distance.
4. Initiate protective actions to the extent possible, beginning with those closest to the spill site and working away from the site in the downwind direction. When a water-reactive PIH producing material is spilled into a river or stream, the source of the toxic gas may move with the current or stretch from the spill point downstream for a substantial distance.

Identification and Control of Hazardous Material



TABLE 3
Classes of Flammable Materials

Hazardous Class	Definition	Examples
Flammable Liquid	Any liquid with a flash point below 37.8°C (100°F).	Gasoline, pentane
Flammable Solid	Any solid material, other than one classified as an explosive, which is likely to cause fire by self-ignition through friction, absorption of moisture, chemical changes, or retained heat. Can be ignited readily and burn vigorously.	Phosphorus, fish meal
Flammable Solid (Dangerous when wet)	Same definition as above, with the additional fact that water will accelerate the reaction.	Magnesium scrap, lithium silicon
Flammable Gases	Any mixture or material in a container having an absolute pressure exceeding 40 psi at 70°F or any liquid flammable material having a vapor pressure exceeding 40 psi at 100°F.	Methane, methyl chloride
Combustible Liquid	Any liquid with a flash point at or above 37.8°C (100°F) and below 93.3°C (200°F).	Pine oil, ink, fuel oil

TABLE 4
Classification of Flammable and Combustible Liquids (NFPA-30)

Class I	Flammable Liquids—Flash point below 100°F (37.8°C)
	<i>Volatile Class I Flammable Liquids</i>
Class IA	Most hazardous, having flash points below 73°F (22.8°C) with boiling points below 100°F (37.8°C)
Class IB	Same flash point range but with boiling points at or above 100°F (37.8°C)
Class IC	Flash points between 73°F (22.8°C) and below 100°F (37.8°C)

Class II	Combustible Liquids—Flash points at or above 100°F (37.8°C) and below 140°F (60°C)
Class III	Liquids are included in the combustible liquid classification and are further classified
Class IIIA	Flash point between 140 and 200°F (60–93.4°C)
Class IIIB	Flash point 200°F (93.4°C) or above

NFPA CODE 704:

NFPA 704 provides an easy method of recognizing hazards. The NFPA 704 Diamond indicates the health, flammability, and reactivity (i.e., stability) hazards of chemicals by placing numbers in the three upper squares of the diamond

Health Hazards Are Indicated in the Left Square, Color-Coded Blue

4. Materials which on very short exposure could cause death or major residual injury.
3. Materials which on short exposure could cause serious temporary or residual injury.
2. Materials which on intense or continued, but not chronic, exposure could cause temporary incapacitation or possible residual injury.
1. Materials which on exposure would cause irritation but only minor residual injury.
0. Materials which on exposure under fire conditions would offer no hazard beyond that of ordinary combustible material.

Flammability Hazards Are Indicated in the Top Square, Color-Coded Red

4. Materials which will vaporize rapidly or completely at atmospheric pressure and normal ambient temperature, or which are dispersed readily and which will burn readily.
3. Liquids and solids which can be ignited under almost all ambient temperature conditions.
2. Materials which must be heated moderately or exposed to relatively high ambient temperatures before ignition can occur.
1. Materials which must be preheated before ignition can occur.
0. Materials that will not burn.

Reactivity (Stability) Hazards Are Indicated in the Right Square, Color-Coded Yellow

4. Materials which in themselves are readily capable of detonations or of explosive decomposition or reaction at normal temperatures and pressures.
3. Materials which in themselves are capable of detonation or explosive decomposition or reaction, but require a strong initiating source, or which must be heated under confinement before initiation, or which react explosively with water.
2. Materials which readily undergo violent chemical change at elevated temperatures, or which react violently with water, or which may form explosive mixtures with water.
1. Materials which in themselves are normally stable, but which can become unstable at elevated temperatures and pressures.
0. Materials which in themselves are normally stable, even under fire exposure conditions, and which are not reactive with water.

Special Information Is Indicated in the Bottom Square, Color-Coded White

0. The letter W with a bar through it indicates a material may have a hazardous reaction with water. This does not mean “use no water,” but rather “avoid the use of water.” Note that some forms of water (e.g., fog or fine spray) may be used. Because water may cause a hazard, it is advised that water be used very cautiously until fire fighters have proper information.

1. The radioactive “pinwheel” indicates radioactive materials.
2. The letters “OX” indicate an oxidizer.



HAZARD DIAMOND

TABLE 5
Classes of Oxidizing Materials

Hazardous Class	Definition	Examples
Oxidizer	A substance that yields O ₂ readily to stimulate the combustion of organic matter.	Silver nitrate
Organic Peroxide	An organic derivative of the inorganic compound, hydrogen peroxide.	Lauroyl peroxide
Oxygen	An odorless, colorless, gaseous chemical element that supports combustion. At low temperatures the gas liquefies.	Oxygen


TABLE 6
Classes of Explosives

Hazardous Class	Definition	Examples
Explosive	Any chemical compound, mixture, or device, the purpose of which is to function by explosion, that is, with substantial instantaneous release of gas or heat.	
Class A	A detonating or otherwise maximum hazard.	Black powder, dynamite, blasting caps
Class B	Function by rapid combustion rather than detonation.	Special fireworks, flash powders
Class C	Materials that do not ordinarily detonate in restricted quantities—minimum explosion hazard.	Flares, small arms

FIRE PREVENTION & PROTECTION:

FIRE PREVENTION

Fire prevention requires segregating the three elements of the fire triangle. A fire needs three elements - heat, oxygen and fuel. Without heat, oxygen and fuel a fire will not start or spread. A key strategy to prevent fire is to remove one or more of heat, oxygen or fuel. .



HEAT

Heat can be generated by work processes and is an essential part of some processes such as cooking. This heat must be controlled and kept away from fuel unless carefully controlled. Heat generated as a by-product of a process must be dealt with properly.


Heat Safeguards

- Ensure employees are aware of their responsibility to report dangers
- Control sources of ignition
- Have chimneys inspected and cleaned regularly
- Treat independent building uses, such as an office over a shop as separate purpose groups and therefore compartmentalize from each other
- Ensure cooking food is always attended
- Use the Electricity Supply Board's Safety webpage
- Have regard to relevant Authority Safety Alerts, e.g. Mobile Phone "*Expert XP-Ex-1*", Filling LPG Cylinders
- Use the Code of Practice For Avoiding Danger From Underground Services

OXYGEN

Oxygen gas is used

- in welding, flame cutting and other similar processes
- for helping people with breathing difficulties
- in hyperbaric chambers as a medical treatment
- in decompression chambers
- for food preservation and packaging
- in steelworks and chemical plants



The air we breathe contains about 21% oxygen. Pure oxygen at high pressure, such as from a cylinder, can react violently with common materials such as oil and grease. Other materials may catch fire spontaneously. Nearly all materials including textiles, rubber and even metals will burn vigorously in oxygen.

With even a small increase in the oxygen level in the air to 24%, it becomes easier to start a fire, which will then burn hotter and more fiercely than in normal air. It may be almost impossible to put the fire out. A leaking valve or hose in a poorly ventilated room or confined space can quickly increase the oxygen concentration to a dangerous level.

The main causes of fires and explosions when using oxygen are

- oxygen enrichment from leaking equipment
- use of materials not compatible with oxygen
- use of oxygen in equipment not designed for oxygen service
- incorrect or careless operation of oxygen equipment

Oxygen Safeguards

- Ensure employees are aware of their responsibility to report dangers
- See safeguards in the Code of Practice for Working in Confined Spaces
- Oxygen should never be used to “sweeten” the air in a confined space
- **Where oxygen is used,**
 - follow safety advice from the supplier
 - follow the safeguards on the safety data sheet
 - keep the safety data sheet readily available
- Be aware of the dangers of oxygen if in doubt, ask
- Prevent oxygen enrichment by ensuring that equipment is leak-tight and in good working order
- Check that ventilation is adequate
- Always use oxygen cylinders and equipment carefully and correctly
- Always open oxygen cylinder valves slowly
- Do not smoke where oxygen is being used
- Never use replacement parts which have not been specifically approved for oxygen service
- Never use oxygen equipment above the pressures certified by the manufacturer
- Never use oil or grease to lubricate oxygen equipment
- Never use oxygen in equipment which is not designed for oxygen service
- Operators of locations storing large amounts of oxidising substances

FUEL

Workplaces in which large amounts of flammable materials are displayed, stored or used can present a greater hazard than those where the amount kept is small.

In relation to fire, fuel consists of flammable material. Flammable material is material that burns readily in a normal atmosphere. Flammable materials include flammable liquids (e.g. petrol), flammable gasses (e.g. propane and butane) and flammable solids (e.g. charcoal, paper). It is important to identify all flammable materials that are in your workplace so that proper controls can be put in place.



Great care is required in the storage, handling and use of flammable materials. Safety Data sheets may provide detailed advice.

Fuel Safeguards

- Identify all flammable materials so that proper controls can be put in place
- Identify use of substances with flammable vapours (e.g. some adhesives)
- Reduce quantities of flammable materials to the smallest amount necessary for running the business and keep away from escape routes
- Replace highly flammable materials with less flammable ones
- Store remaining stocks of highly flammable materials properly outside, in a separate building, or separated from the main workplace by fire-resisting construction
- Provide clearly marked separate storage for flammable chemicals, gas cylinders, and waste materials
- Train employees on safe storage, handling and use of flammable materials
- Keep stocks of office stationery and supplies and flammable cleaners' materials in separate cupboards or stores. They should be fire-resisting with a fire door if they open onto a corridor or stairway escape route.
- This is highly specialised work and a detailed risk assessment must be conducted
- Detailed work instructions must be put in place
- Advice should be sought from the gas supplier as needed
- Workers must be properly trained and supervised
- The quantity of flammable liquids in workrooms should be kept to a minimum, normally no more than a half-day's or half a shifts supply
- Flammable liquids, including empty or part-used containers, should be stored safely. Small quantities (Tens of Litres) of flammable liquids can be stored in the workroom if in closed containers in a fire-resisting (e.g. metal), bin or cabinet fitted with means to contain any leaks
- Flammable liquids should not be decanted within the store. Decanting should take place in a well-ventilated area set aside for this purpose, with appropriate facilities to contain and clear up any spillage
- Container lids should always be replaced after use, and no container should ever be opened in such a way that it cannot be safely resealed

- Flammable liquids should be stored and handled in well ventilated conditions. Where necessary, additional properly designed exhaust ventilation should be provided to reduce the level of vapour concentration in the air
- Storage containers should be kept covered and proprietary safety containers with self-closing lids should be used for dispensing and applying small quantities of flammable liquids
- There should be no potential ignition sources in areas where flammable liquids are used or stored and flammable concentrations of vapour may be present at any time. Any electrical equipment used in these areas, including fire alarm and emergency lighting systems, needs to be suitable for use in flammable atmospheres
- Avoid accumulations of combustible rubbish and waste and remove at least daily and store away from the building
- Never store flammable or combustible rubbish, even temporarily, in escape routes, or where it can contact potential sources of heat
- Position skips so that a fire will not put any structure at risk
- Clean cooking surfaces on a regular basis to prevent grease build-up
- Rags and cloths which have been used to mop up or apply flammable liquids should be disposed of in metal containers with well-fitting lids and removed from the workplace at the end of each shift or working day
- Handle material in accordance with the advice on the safety data sheet
- Keep safety data sheets readily available
- Keep safety data sheets safely available in the event of a fire so that the information is available for emergency services

FIRE PROTECTION

Fire is a chemical reaction that requires three elements to be present for the reaction to take place and continue. The three elements are:

- Heat, or an ignition source
- Fuel
- Oxygen

These three elements typically are referred to as the “fire triangle.” Fire is the result of the reaction between the fuel and oxygen in the air. Scientists developed the concept of a fire triangle to aid in understanding of the cause of fires and how they can be prevented and extinguished. Heat, fuel and oxygen must combine in a precise way for a fire to start and continue to burn. If one element of the fire triangle is not present or removed, fire will not start or, if already burning, will extinguish.

Ignition sources can include any material, equipment or operation that emits a spark or flame—including obvious items, such as torches, as well as less obvious items, such as static electricity and grinding operations. Equipment or components that radiate heat, such as kettles, catalytic converters and mufflers, also can be ignition sources. Fuel sources include combustible materials, such as wood, paper, trash and clothing; flammable liquids, such as gasoline or solvents; and flammable gases, such as propane or natural gas. Oxygen in the fire triangle comes from the air in the atmosphere. Air contains approximately 79 percent nitrogen and 21 percent oxygen. OSHA describes a hazardous atmosphere as one which is oxygen-deficient because it has less than 19.5 percent oxygen, or oxygen enriched because it has greater than 23.5 percent oxygen. Either instance is regarded by OSHA as an atmosphere immediately dangerous to life and health (IDLH) for reasons unrelated to the presence of fire. Depending on the type of fuel involved, fires can occur with much lower volume of oxygen present than needed to support human respiration. Every roofing project has all three of the fire triangle elements present in abundance. The key to preventing fires is to keep heat and ignition sources away from materials, equipment and structures that could act as fuel to complete the fire triangle.

Fire Classifications Fires are classified as A, B, C, D or K based on the type of substance that is the fuel for the fire, as follows:

Class A—fires involving ordinary combustibles, such as paper, trash, some plastics, wood and cloth. A rule of thumb is if it leaves an ash behind, it is a Class A fire.

Class B—fires involving flammable gases or liquids, such as propane, oil and gasoline


Class C—fires involving energized electrical components

Class D—fires involving metal. A rule of thumb is if the name of the metal ends with the letters “um,” it is a Class D fire. Examples of this are aluminum, magnesium, beryllium and sodium. Class D fires rarely occur in the roofing industry.

Class K—fires involving vegetable or animal cooking oils or fats; common in commercial cooking operations using deep fat fryers.

Fire Extinguishers There are different types of fire extinguishers designed to put out the different classes of fire. Selecting the appropriate fire extinguisher is an important consideration for a roofing contractor. The wrong extinguisher actually may make a fire emergency worse. For example, failing to use a C-rated extinguisher on energized electrical components may endanger workers by causing the extinguishing material to be electrified by the energized components that are on fire. C-rated fire extinguishers put out the fire by using a chemical that does not conduct electricity.

Fire Extinguisher Anatomy




The following table illustrates the types of extinguishers, fire classes for which each is used and the limitations of each extinguisher.

<i>Fire Extinguisher Type</i>	<i>Class of Fire it Extinguishes</i>	<i>Extinguisher Limitations/ Comments</i>
<i>Dry Chemical (multipurpose)</i>	<i>A, B, C</i>	<i>Generally good for use in roofing industry</i>
<i>Foam—alcohol-resistant B and aqueous film-forming foam (AFFF) types</i>		<i>Expensive; effective on Class B only; limited shelf life; generally not needed in roofing industry</i>
<i>Water</i>	<i>A</i>	<i>Good only for Class A fires</i>
<i>Metal X</i>	<i>D</i>	<i>Expensive; must be kept dry; ineffective on A, B, C;</i>
<i>Carbon Dioxide</i>	<i>B, C</i>	<i>If used in confined areas, will create oxygen deficiency; not effective in windy conditions; can cause frostbite during discharge; typically not used in roofing industry</i>
<i>Halon</i>	<i>B, C</i>	<i>Expensive; not effective in windy conditions; toxic gases may be released in extremely hot fires because of decomposition; generally not used in roofing industry</i>
<i>Potassium Acetate</i>	<i>K</i>	<i>Expensive, wet chemical extinguisher for commercial cooking operations using oils and fats</i>

Remember this easy acronym when using an extinguisher - **P.A.S.S.**

Pull the pin.



Aim the nozzle.



Squeeze the handle.



Sweep side to side at the base of the fire.



Employees should be instructed that if a fire cannot be extinguished using one full extinguisher, they should evacuate the site and let the fire department handle the situation.

EMERGENCY EVACUATION

Emergency evacuation is the urgent immediate egress or escape of people away from an area that contains an imminent threat, an ongoing threat or a hazard to lives or property.

Examples range from the small-scale evacuation of a building due to a storm or fire to the large-scale evacuation of a city because of a flood, bombardment or approaching weather system, especially a Tropical Cyclone. In situations involving hazardous materials or possible contamination, evacuees may be decontaminated prior to being transported out of the contaminated area.

Evacuation Sequence-

The sequence of an evacuation can be divided into the following phases:

1. detection
2. decision
3. alarm
4. reaction
5. movement to an area of refuge or an assembly station
6. transportation

The time for the first four phases is usually called pre-movement time. The most common equipment in buildings to facilitate emergency evacuations are fire alarms, exit signs, and emergency lights. Some structures need special emergency exits or fire escapes to ensure the availability of alternative escape paths.